

CÁLCULO ÍNDICE DE SOBRE - ESFUERZO COLUMNAS

ÍNDICE DE SOBRESFUERZO COLUMNAS:

7,89

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story3	C1	Col 25x25	0	0,642	1,00	B.2.4-5d	10,16	B.2.4-7h	0,055	B.2.4-7h	0,055	0,095
Story3	C1	Col 25x25	122,5	0,266	0,42	B.2.4-5h	10,16	B.2.4-7h	0,055	B.2.4-7h	0,055	
Story3	C1	Col 25x25	245	0,807	1,26	B.2.4-5d	10,16	B.2.4-7h	0,055	B.2.4-7h	0,055	0,095
Story3	C2	Col 25x25	0	0,823	1,29	B.2.4-5d	10,16	B.2.4-5h	0,061	B.2.4-7h	0,055	0,095
Story3	C2	Col 25x25	122,5	0,204	0,32	B.2.4-7h	10,16	B.2.4-5h	0,061	B.2.4-7h	0,055	
Story3	C2	Col 25x25	245	0,987	1,54	B.2.4-5d	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	0,095
Story3	C3	Col 25x25	0	1,637	2,56	B.2.4-5h	10,16	B.2.4-7h	0,062	B.2.4-5h	0,073	0,095
Story3	C3	Col 25x25	122,5	0,284	0,44	B.2.4-5d	10,16	B.2.4-7h	0,062	B.2.4-5h	0,073	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story3	C3	Col 25x25	245	1,488	2,33	B.2.4-5h	10,16	B.2.4-5d	0,062	B.2.4-5h	0,073	0,095
Story3	C4	Col 25x25	0	1,573	2,46	B.2.4-5h	10,16	B.2.4-7h	0,062	B.2.4-5h	0,07	0,095
Story3	C4	Col 25x25	122,5	0,336	0,53	B.2.4-5d	10,16	B.2.4-7h	0,062	B.2.4-5h	0,07	
Story3	C4	Col 25x25	245	1,511	2,36	B.2.4-5h	10,16	B.2.4-7h	0,061	B.2.4-5h	0,07	0,095
Story3	C5	Col 25x25	0	0,867	1,35	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-7h	0,055	0,095
Story3	C5	Col 25x25	122,5	0,257	0,40	B.2.4-5d	10,16	B.2.4-5h	0,061	B.2.4-7h	0,055	
Story3	C5	Col 25x25	245	1,084	1,69	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-7h	0,055	0,095
Story3	C6	Col 25x25	0	0,78	1,22	B.2.4-5d	10,16	B.2.4-5h	0,061	B.2.4-7h	0,055	0,095
Story3	C6	Col 25x25	122,5	0,169	0,26	B.2.4-7h	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story3	C6	Col 25x25	245	0,924	1,44	B.2.4-5d	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	0,095
Story3	C7	Col 25x25	0	1,268	1,98	B.2.4-5h	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	0,095
Story3	C7	Col 25x25	122,5	0,2	0,31	B.2.4-5h	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	
Story3	C7	Col 25x25	245	1,249	1,95	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-5h	0,061	0,095
Story3	C8	Col 25x25	0	1,186	1,85	B.2.4-5h	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	0,095
Story3	C8	Col 25x25	122,5	0,194	0,30	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-5h	0,061	
Story3	C8	Col 25x25	245	1,229	1,92	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-5h	0,061	0,095
Story3	C9	Col 25x25	0	0,774	1,21	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-7h	0,055	0,095
Story3	C9	Col 25x25	122,5	0,214	0,33	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-7h	0,055	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story3	C9	Col 25x25	245	0,992	1,55	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-7h	0,055	0,095
Story3	C10	Col 25x25	0	0,823	1,29	B.2.4-5d	10,16	B.2.4-5h	0,061	B.2.4-7h	0,055	0,095
Story3	C10	Col 25x25	122,5	0,167	0,26	B.2.4-7h	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	
Story3	C10	Col 25x25	245	0,942	1,47	B.2.4-5d	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	0,095
Story3	C11	Col 25x25	0	1,247	1,95	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-5h	0,061	0,095
Story3	C11	Col 25x25	122,5	0,183	0,29	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-5h	0,061	
Story3	C11	Col 25x25	245	1,228	1,92	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-5h	0,061	0,095
Story3	C12	Col 25x25	0	1,121	1,75	B.2.4-5d	10,16	B.2.4-5d	0,061	B.2.4-7h	0,055	0,095
Story3	C12	Col 25x25	122,5	0,303	0,47	B.2.4-5h	10,16	B.2.4-5d	0,061	B.2.4-7h	0,055	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story3	C12	Col 25x25	245	1,09	1,70	B.2.4-5d	10,16	B.2.4-5d	0,061	B.2.4-7h	0,055	0,095
Story3	C13	Col 25x25	0	0,722	1,13	B.2.4-5d	10,16	B.2.4-5h	0,061	B.2.4-7h	0,055	0,095
Story3	C13	Col 25x25	122,5	0,152	0,24	B.2.4-5h	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	
Story3	C13	Col 25x25	245	0,877	1,37	B.2.4-5d	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	0,095
Story3	C14	Col 25x25	0	1,217	1,90	B.2.4-5h	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	0,095
Story3	C14	Col 25x25	122,5	0,204	0,32	B.2.4-5h	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	
Story3	C14	Col 25x25	245	1,183	1,85	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-5h	0,061	0,095
Story3	C15	Col 25x25	0	1,178	1,84	B.2.4-5h	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	0,095
Story3	C15	Col 25x25	122,5	0,207	0,32	B.2.4-5h	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story3	C15	Col 25x25	245	1,184	1,85	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-5h	0,061	0,095
Story3	C16	Col 25x25	0	0,699	1,09	B.2.4-5d	10,16	B.2.4-5h	0,061	B.2.4-7h	0,055	0,095
Story3	C16	Col 25x25	122,5	0,188	0,29	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-7h	0,055	
Story3	C16	Col 25x25	245	0,892	1,39	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-7h	0,055	0,095
Story3	C17	Col 25x25	0	0,714	1,12	B.2.4-5d	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	0,095
Story3	C17	Col 25x25	122,5	0,143	0,22	B.2.4-5h	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	
Story3	C17	Col 25x25	245	0,86	1,34	B.2.4-5d	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	0,095
Story3	C18	Col 25x25	0	1,172	1,83	B.2.4-5h	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	0,095
Story3	C18	Col 25x25	122,5	0,2	0,31	B.2.4-5h	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story3	C18	Col 25x25	245	1,125	1,76	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-5h	0,061	0,095
Story3	C19	Col 25x25	0	1,156	1,81	B.2.4-5h	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	0,095
Story3	C19	Col 25x25	122,5	0,206	0,32	B.2.4-5h	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	
Story3	C19	Col 25x25	245	1,132	1,77	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-5h	0,061	0,095
Story3	C20	Col 25x25	0	0,749	1,17	B.2.4-5d	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	0,095
Story3	C20	Col 25x25	122,5	0,161	0,25	B.2.4-5h	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	
Story3	C20	Col 25x25	245	0,919	1,44	B.2.4-5d	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	0,095
Story3	C22	Col 25x25	0	0,59	0,92	B.2.4-5h	10,16	B.2.4-7h	0,055	B.2.4-7h	0,055	0,095
Story3	C22	Col 25x25	122,5	0,236	0,37	B.2.4-5h	10,16	B.2.4-7h	0,055	B.2.4-7h	0,055	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story3	C22	Col 25x25	245	0,768	1,20	B.2.4-5h	10,16	B.2.4-7h	0,055	B.2.4-7h	0,055	0,095
Story3	C23	Col 25x25	0	0,819	1,28	B.2.4-5h	10,16	B.2.4-7h	0,055	B.2.4-5d	0,06	0,095
Story3	C23	Col 25x25	122,5	0,13	0,20	B.2.4-5d	10,16	B.2.4-7h	0,055	B.2.4-5d	0,06	
Story3	C23	Col 25x25	245	0,926	1,45	B.2.4-5h	10,16	B.2.4-7h	0,055	B.2.4-5d	0,06	0,095
Story3	C24	Col 25x25	0	0,913	1,43	B.2.4-5h	10,16	B.2.4-5d	0,059	B.2.4-5d	0,059	0,095
Story3	C24	Col 25x25	122,5	0,081	0,13	B.2.4-5d	10,16	B.2.4-5d	0,059	B.2.4-5d	0,059	
Story3	C24	Col 25x25	245	0,976	1,53	B.2.4-5h	10,16	B.2.4-5d	0,059	B.2.4-5d	0,059	0,095
Story3	C25	Col 25x25	0	1,148	1,79	B.2.4-5h	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	0,095
Story3	C25	Col 25x25	122,5	0,192	0,30	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-5h	0,061	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story3	C25	Col 25x25	245	1,108	1,73	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-5h	0,061	0,095
Story3	C26	Col 25x25	0	1,119	1,75	B.2.4-5h	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	0,095
Story3	C26	Col 25x25	122,5	0,201	0,31	B.2.4-5h	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	
Story3	C26	Col 25x25	245	1,098	1,72	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-5h	0,061	0,095
Story3	C27	Col 25x25	0	0,732	1,14	B.2.4-5d	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	0,095
Story3	C27	Col 25x25	122,5	0,16	0,25	B.2.4-5h	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	
Story3	C27	Col 25x25	245	0,915	1,43	B.2.4-5d	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	0,095
Story3	C28	Col 25x25	0	0,841	1,31	B.2.4-5d	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	0,095
Story3	C28	Col 25x25	122,5	0,172	0,27	B.2.4-5h	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story3	C28	Col 25x25	245	0,939	1,47	B.2.4-5d	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	0,095
Story3	C29	Col 25x25	0	1,127	1,76	B.2.4-5d	10,16	B.2.4-5d	0,061	B.2.4-5d	0,061	0,095
Story3	C29	Col 25x25	122,5	0,127	0,20	B.2.4-5h	10,16	B.2.4-5d	0,061	B.2.4-5d	0,061	
Story3	C29	Col 25x25	245	1,152	1,80	B.2.4-5d	10,16	B.2.4-5d	0,061	B.2.4-5d	0,061	0,095
Story3	C30	Col 25x25	0	0,983	1,54	B.2.4-5d	10,16	B.2.4-5d	0,061	B.2.4-5d	0,061	0,095
Story3	C30	Col 25x25	122,5	0,08	0,13	B.2.4-5d	10,16	B.2.4-5d	0,061	B.2.4-5d	0,061	
Story3	C30	Col 25x25	245	1,069	1,67	B.2.4-5d	10,16	B.2.4-5d	0,061	B.2.4-5d	0,061	0,095
Story3	C31	Col 25x25	0	1,267	1,98	B.2.4-5h	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	0,095
Story3	C31	Col 25x25	122,5	0,233	0,36	B.2.4-5d	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story3	C31	Col 25x25	245	1,178	1,84	B.2.4-5d	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	0,095
Story3	C36	Col 25x25	0	1,224	1,91	B.2.4-5d	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	0,095
Story3	C36	Col 25x25	122,5	0,231	0,36	B.2.4-5d	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	
Story3	C36	Col 25x25	245	1,15	1,80	B.2.4-5d	10,16	B.2.4-5h	0,061	B.2.4-5h	0,061	0,095
Story3	C37	Col 25x25	0	0,756	1,18	B.2.4-5d	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	0,095
Story3	C37	Col 25x25	122,5	0,15	0,23	B.2.4-5h	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	
Story3	C37	Col 25x25	245	0,936	1,46	B.2.4-5d	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	0,095
Story3	C40	Col 25x25	0	1,344	2,10	B.2.4-5d	10,16	B.2.4-5h	0,062	B.2.4-5h	0,062	0,095
Story3	C40	Col 25x25	122,5	0,222	0,35	B.2.4-5h	10,16	B.2.4-5h	0,061	B.2.4-5h	0,061	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story3	C40	Col 25x25	245	1,262	1,97	B.2.4-5d	10,16	B.2.4-5h	0,061	B.2.4-5h	0,061	0,095
Story3	C41	Col 25x25	0	0,815	1,27	B.2.4-5d	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	0,095
Story3	C41	Col 25x25	122,5	0,149	0,23	B.2.4-5h	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	
Story3	C41	Col 25x25	245	0,998	1,56	B.2.4-5d	10,16	B.2.4-5h	0,06	B.2.4-7h	0,055	0,095
Story3	C42	Col 25x25	0	0,889	1,39	B.2.4-5d	10,16	B.2.4-5d	0,062	B.2.4-5d	0,062	0,095
Story3	C42	Col 25x25	122,5	0,222	0,35	B.2.4-5d	10,16	B.2.4-5d	0,062	B.2.4-5d	0,062	
Story3	C42	Col 25x25	245	0,921	1,44	B.2.4-5d	10,16	B.2.4-5d	0,062	B.2.4-5d	0,062	0,095
Story3	C43	Col 25x25	0	1,137	1,78	B.2.4-5d	10,16	B.2.4-5d	0,061	B.2.4-5d	0,061	0,095
Story3	C43	Col 25x25	122,5	0,129	0,20	B.2.4-5h	10,16	B.2.4-5d	0,061	B.2.4-5d	0,061	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story3	C43	Col 25x25	245	1,169	1,83	B.2.4-5d	10,16	B.2.4-5d	0,061	B.2.4-5d	0,061	0,095
Story3	C44	Col 25x25	0	1,023	1,60	B.2.4-5d	10,16	B.2.4-5d	0,061	B.2.4-5d	0,061	0,095
Story3	C44	Col 25x25	122,5	0,079	0,12	B.2.4-5d	10,16	B.2.4-5d	0,061	B.2.4-5d	0,061	
Story3	C44	Col 25x25	245	1,106	1,73	B.2.4-5d	10,16	B.2.4-5d	0,061	B.2.4-5d	0,061	0,095
Story3	C46	Col 25x25	0	0,582	0,91	B.2.4-5d	10,16	B.2.4-7h	0,055	B.2.4-7h	0,055	0,095
Story3	C46	Col 25x25	122,5	0,247	0,39	B.2.4-5d	10,16	B.2.4-7h	0,055	B.2.4-7h	0,055	
Story3	C46	Col 25x25	245	0,787	1,23	B.2.4-5d	10,16	B.2.4-7h	0,055	B.2.4-7h	0,055	0,095
Story3	C47	Col 25x25	0	0,789	1,23	B.2.4-5h	10,16	B.2.4-7h	0,055	B.2.4-5d	0,06	0,095
Story3	C47	Col 25x25	122,5	0,143	0,22	B.2.4-5d	10,16	B.2.4-7h	0,055	B.2.4-5d	0,06	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story3	C47	Col 25x25	245	0,903	1,41	B.2.4-5d	10,16	B.2.4-7h	0,055	B.2.4-5d	0,06	0,095
Story3	C48	Col 25x25	0	0,763	1,19	B.2.4-5h	10,16	B.2.4-7h	0,055	B.2.4-5d	0,06	0,095
Story3	C48	Col 25x25	122,5	0,147	0,23	B.2.4-7d	10,16	B.2.4-7h	0,055	B.2.4-5d	0,06	
Story3	C48	Col 25x25	245	0,896	1,40	B.2.4-5d	10,16	B.2.4-7h	0,055	B.2.4-5d	0,059	0,095
Story3	C49	Col 25x25	0	0,841	1,31	B.2.4-5h	10,16	B.2.4-7h	0,055	B.2.4-5d	0,061	0,095
Story3	C49	Col 25x25	122,5	0,204	0,32	B.2.4-5d	10,16	B.2.4-7h	0,055	B.2.4-5d	0,061	
Story3	C49	Col 25x25	245	0,968	1,51	B.2.4-5d	10,16	B.2.4-7h	0,055	B.2.4-5d	0,06	0,095
Story3	C50	Col 25x25	0	0,79	1,23	B.2.4-5h	10,16	B.2.4-7h	0,055	B.2.4-5d	0,061	0,095
Story3	C50	Col 25x25	122,5	0,216	0,34	B.2.4-5d	10,16	B.2.4-7h	0,055	B.2.4-5d	0,061	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story3	C50	Col 25x25	245	0,921	1,44	B.2.4-5d	10,16	B.2.4-7h	0,055	B.2.4-5d	0,061	0,095
Story3	C51	Col 25x25	0	0,448	0,70	B.2.4-5h	10,16	B.2.4-7h	0,055	B.2.4-7h	0,055	0,095
Story3	C51	Col 25x25	122,5	0,22	0,34	B.2.4-5d	10,16	B.2.4-7h	0,055	B.2.4-7h	0,055	
Story3	C51	Col 25x25	245	0,747	1,17	B.2.4-5d	10,16	B.2.4-7h	0,055	B.2.4-7h	0,055	0,095
Story3	C54	Col 25x25	0	1,347	2,10	B.2.4-5d	10,16	B.2.4-5d	0,062	B.2.4-5d	0,062	0,095
Story3	C54	Col 25x25	122,5	0,225	0,35	B.2.4-5d	10,16	B.2.4-5d	0,062	B.2.4-5d	0,062	
Story3	C54	Col 25x25	245	1,25	1,95	B.2.4-5d	10,16	B.2.4-5d	0,062	B.2.4-5d	0,062	0,095
Story2	C1	Col 25x25	0	1,87	2,92	B.2.4-5d	10,16	B.2.4-5d	0,063	B.2.4-5h	0,071	0,095
Story2	C1	Col 25x25	122,5	0,29	0,45	B.2.4-7d	10,16	B.2.4-5d	0,063	B.2.4-5h	0,071	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story2	C1	Col 25x25	245	1,797	2,81	B.2.4-5d	10,16	B.2.4-5d	0,063	B.2.4-5h	0,071	0,095
Story2	C2	Col 25x25	0	2,198	3,43	B.2.4-5d	10,16	B.2.4-5d	0,079	B.2.4-5h	0,083	0,095
Story2	C2	Col 25x25	122,5	0,268	0,42	B.2.4-7h	10,16	B.2.4-5d	0,079	B.2.4-5h	0,083	
Story2	C2	Col 25x25	245	1,999	3,12	B.2.4-5d	10,16	B.2.4-5d	0,079	B.2.4-5h	0,083	0,095
Story2	C3	Col 25x25	0	3,787	5,92	B.2.4-5h	10,16	B.2.4-7h	0,062	B.2.4-7h	0,136	0,095
Story2	C3	Col 25x25	122,5	0,475	0,74	B.2.4-5h	10,16	B.2.4-7h	0,062	B.2.4-7h	0,136	
Story2	C3	Col 25x25	245	3,244	5,07	B.2.4-5h	10,16	B.2.4-7h	0,062	B.2.4-7h	0,136	0,095
Story2	C4	Col 25x25	0	3,635	5,68	B.2.4-5h	10,16	B.2.4-7h	0,021	B.2.4-5h	0,084	0,095
Story2	C4	Col 25x25	122,5	0,459	0,72	B.2.4-5h	10,16	B.2.4-7h	0,021	B.2.4-5h	0,084	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story2	C4	Col 25x25	245	3,221	5,03	B.2.4-5h	10,16	B.2.4-7h	0,021	B.2.4-5h	0,084	0,095
Story2	C5	Col 25x25	0	2,274	3,55	B.2.4-5h	10,16	B.2.4-5d	0,06	B.2.4-5h	0,094	0,095
Story2	C5	Col 25x25	122,5	0,232	0,36	B.2.4-5h	10,16	B.2.4-5d	0,06	B.2.4-5h	0,094	
Story2	C5	Col 25x25	245	2,185	3,41	B.2.4-5h	10,16	B.2.4-5d	0,06	B.2.4-5h	0,094	0,095
Story2	C6	Col 25x25	0	2,019	3,15	B.2.4-5d	10,16	B.2.4-5d	0,075	B.2.4-5h	0,077	0,095
Story2	C6	Col 25x25	122,5	0,202	0,32	B.2.4-5h	10,16	B.2.4-5d	0,075	B.2.4-5h	0,077	
Story2	C6	Col 25x25	245	1,831	2,86	B.2.4-5h	10,16	B.2.4-5d	0,075	B.2.4-5h	0,077	0,095
Story2	C7	Col 25x25	0	3,096	4,84	B.2.4-5h	10,16	B.2.4-7d	0,079	B.2.4-7h	0,114	0,095
Story2	C7	Col 25x25	122,5	0,377	0,59	B.2.4-5h	10,16	B.2.4-7d	0,079	B.2.4-7h	0,114	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story2	C7	Col 25x25	245	2,681	4,19	B.2.4-5h	10,16	B.2.4-7d	0,079	B.2.4-7h	0,114	0,095
Story2	C8	Col 25x25	0	3,013	4,71	B.2.4-5h	10,16	B.2.4-7d	0,036	B.2.4-5h	0,061	0,095
Story2	C8	Col 25x25	122,5	0,381	0,60	B.2.4-5h	10,16	B.2.4-7d	0,037	B.2.4-5h	0,061	
Story2	C8	Col 25x25	245	2,643	4,13	B.2.4-5h	10,16	B.2.4-7d	0,037	B.2.4-5h	0,061	0,095
Story2	C9	Col 25x25	0	2,119	3,31	B.2.4-5h	10,16	B.2.4-5d	0,075	B.2.4-5h	0,081	0,095
Story2	C9	Col 25x25	122,5	0,239	0,37	B.2.4-5h	10,16	B.2.4-5d	0,075	B.2.4-5h	0,081	
Story2	C9	Col 25x25	245	2,015	3,15	B.2.4-5h	10,16	B.2.4-5d	0,075	B.2.4-5h	0,081	0,095
Story2	C10	Col 25x25	0	2,063	3,22	B.2.4-5d	10,16	B.2.4-5d	0,081	B.2.4-5h	0,072	0,095
Story2	C10	Col 25x25	122,5	0,215	0,34	B.2.4-7h	10,16	B.2.4-5d	0,081	B.2.4-5h	0,072	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story2	C10	Col 25x25	245	1,832	2,86	B.2.4-5d	10,16	B.2.4-5d	0,081	B.2.4-5h	0,072	0,095
Story2	C11	Col 25x25	0	2,982	4,66	B.2.4-5h	10,16	B.2.4-7d	0,081	B.2.4-7h	0,109	0,095
Story2	C11	Col 25x25	122,5	0,343	0,54	B.2.4-5h	10,16	B.2.4-7d	0,081	B.2.4-7h	0,109	
Story2	C11	Col 25x25	245	2,568	4,01	B.2.4-5h	10,16	B.2.4-7d	0,081	B.2.4-7h	0,109	0,095
Story2	C12	Col 25x25	0	2,629	4,11	B.2.4-5d	10,16	B.2.4-7d	0,089	B.2.4-7h	0,074	0,095
Story2	C12	Col 25x25	122,5	0,293	0,46	B.2.4-5h	10,16	B.2.4-7d	0,089	B.2.4-7h	0,074	
Story2	C12	Col 25x25	245	2,339	3,65	B.2.4-5d	10,16	B.2.4-7d	0,089	B.2.4-7h	0,074	0,095
Story2	C13	Col 25x25	0	1,782	2,78	B.2.4-5d	10,16	B.2.4-5d	0,069	B.2.4-5h	0,068	0,095
Story2	C13	Col 25x25	122,5	0,191	0,30	B.2.4-5h	10,16	B.2.4-5d	0,069	B.2.4-5h	0,068	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story2	C13	Col 25x25	245	1,641	2,56	B.2.4-5h	10,16	B.2.4-5d	0,069	B.2.4-5h	0,068	0,095
Story2	C14	Col 25x25	0	2,835	4,43	B.2.4-5h	10,16	B.2.4-7h	0,021	B.2.4-5h	0,06	0,095
Story2	C14	Col 25x25	122,5	0,377	0,59	B.2.4-5h	10,16	B.2.4-7h	0,021	B.2.4-5h	0,06	
Story2	C14	Col 25x25	245	2,468	3,86	B.2.4-5h	10,16	B.2.4-7h	0,021	B.2.4-5h	0,06	0,095
Story2	C15	Col 25x25	0	2,823	4,41	B.2.4-5h	10,16	B.2.4-7d	0,025	B.2.4-5h	0,052	0,095
Story2	C15	Col 25x25	122,5	0,38	0,59	B.2.4-5h	10,16	B.2.4-7d	0,025	B.2.4-5h	0,053	
Story2	C15	Col 25x25	245	2,49	3,89	B.2.4-5h	10,16	B.2.4-7d	0,025	B.2.4-5h	0,053	0,095
Story2	C16	Col 25x25	0	1,898	2,97	B.2.4-5d	10,16	B.2.4-5d	0,074	B.2.4-5h	0,07	0,095
Story2	C16	Col 25x25	122,5	0,213	0,33	B.2.4-5h	10,16	B.2.4-5d	0,074	B.2.4-5h	0,07	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story2	C16	Col 25x25	245	1,802	2,82	B.2.4-5h	10,16	B.2.4-5d	0,074	B.2.4-5h	0,07	0,095
Story2	C17	Col 25x25	0	1,769	2,76	B.2.4-5d	10,16	B.2.4-5d	0,07	B.2.4-5h	0,065	0,095
Story2	C17	Col 25x25	122,5	0,182	0,28	B.2.4-5h	10,16	B.2.4-5d	0,07	B.2.4-5h	0,065	
Story2	C17	Col 25x25	245	1,608	2,51	B.2.4-5d	10,16	B.2.4-5d	0,07	B.2.4-5h	0,065	0,095
Story2	C18	Col 25x25	0	2,711	4,24	B.2.4-5h	10,16	B.2.4-7h	0,021	B.2.4-5h	0,054	0,095
Story2	C18	Col 25x25	122,5	0,371	0,58	B.2.4-5h	10,16	B.2.4-7h	0,021	B.2.4-5h	0,054	
Story2	C18	Col 25x25	245	2,351	3,67	B.2.4-5h	10,16	B.2.4-7h	0,021	B.2.4-5h	0,054	0,095
Story2	C19	Col 25x25	0	2,762	4,32	B.2.4-5h	10,16	B.2.4-7d	0,026	B.2.4-5h	0,051	0,095
Story2	C19	Col 25x25	122,5	0,368	0,58	B.2.4-5h	10,16	B.2.4-7d	0,026	B.2.4-5h	0,051	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story2	C19	Col 25x25	245	2,412	3,77	B.2.4-5h	10,16	B.2.4-7d	0,026	B.2.4-5h	0,051	0,095
Story2	C20	Col 25x25	0	2,016	3,15	B.2.4-5d	10,16	B.2.4-5d	0,084	B.2.4-5h	0,063	0,095
Story2	C20	Col 25x25	122,5	0,182	0,28	B.2.4-5h	10,16	B.2.4-5d	0,084	B.2.4-5h	0,063	
Story2	C20	Col 25x25	245	1,856	2,90	B.2.4-5d	10,16	B.2.4-5d	0,084	B.2.4-5h	0,063	0,095
Story2	C22	Col 25x25	0	1,67	2,61	B.2.4-5h	10,16	B.2.4-5d	0,057	B.2.4-5h	0,061	0,095
Story2	C22	Col 25x25	122,5	0,222	0,35	B.2.4-5h	10,16	B.2.4-5d	0,057	B.2.4-5h	0,061	
Story2	C22	Col 25x25	245	1,511	2,36	B.2.4-5h	10,16	B.2.4-5d	0,057	B.2.4-5h	0,061	0,095
Story2	C23	Col 25x25	0	1,94	3,03	B.2.4-5h	10,16	B.2.4-5d	0,055	B.2.4-5h	0,08	0,095
Story2	C23	Col 25x25	122,5	0,178	0,28	B.2.4-5d	10,16	B.2.4-5d	0,055	B.2.4-5h	0,08	
Story2	C23	Col 25x25	245	1,759	2,75	B.2.4-5h	10,16	B.2.4-5d	0,055	B.2.4-5h	0,08	0,095

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story2	C24	Col 25x25	0	2,166	3,38	B.2.4-5h	10,16	B.2.4-5d	0,074	B.2.4-5h	0,084	0,095
Story2	C24	Col 25x25	122,5	0,165	0,26	B.2.4-5h	10,16	B.2.4-5d	0,074	B.2.4-5h	0,084	
Story2	C24	Col 25x25	245	1,881	2,94	B.2.4-5h	10,16	B.2.4-5d	0,074	B.2.4-5h	0,084	0,095
Story2	C25	Col 25x25	0	2,602	4,07	B.2.4-5d	10,16	B.2.4-7d	0,025	B.2.4-5h	0,047	0,095
Story2	C25	Col 25x25	122,5	0,344	0,54	B.2.4-5h	10,16	B.2.4-7d	0,025	B.2.4-5h	0,048	
Story2	C25	Col 25x25	245	2,271	3,55	B.2.4-5d	10,16	B.2.4-7d	0,025	B.2.4-5h	0,048	0,095
Story2	C26	Col 25x25	0	2,663	4,16	B.2.4-5h	10,16	B.2.4-7d	0,025	B.2.4-5h	0,045	0,095
Story2	C26	Col 25x25	122,5	0,366	0,57	B.2.4-5h	10,16	B.2.4-7d	0,025	B.2.4-5h	0,046	
Story2	C26	Col 25x25	245	2,326	3,63	B.2.4-5h	10,16	B.2.4-7d	0,025	B.2.4-5h	0,046	0,095
Story2	C27	Col 25x25	0	1,987	3,10	B.2.4-5d	10,16	B.2.4-5d	0,081	B.2.4-5h	0,061	0,095

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story2	C27	Col 25x25	122,5	0,182	0,28	B.2.4-5h	10,16	B.2.4-5d	0,081	B.2.4-5h	0,061	
Story2	C27	Col 25x25	245	1,842	2,88	B.2.4-5d	10,16	B.2.4-5d	0,081	B.2.4-5h	0,061	0,095
Story2	C28	Col 25x25	0	2,705	4,23	B.2.4-5d	10,16	B.2.4-7d	0,032	B.2.4-5h	0,026	0,095
Story2	C28	Col 25x25	122,5	0,376	0,59	B.2.4-5d	10,16	B.2.4-7d	0,032	B.2.4-5h	0,026	
Story2	C28	Col 25x25	245	2,114	3,30	B.2.4-5h	10,16	B.2.4-7d	0,032	B.2.4-5h	0,027	0,095
Story2	C29	Col 25x25	0	2,586	4,04	B.2.4-5d	10,16	B.2.4-7d	0,034	B.2.4-5h	0,034	0,095
Story2	C29	Col 25x25	122,5	0,322	0,50	B.2.4-5d	10,16	B.2.4-7d	0,034	B.2.4-5h	0,034	
Story2	C29	Col 25x25	245	2,222	3,47	B.2.4-5d	10,16	B.2.4-7d	0,034	B.2.4-5h	0,034	0,095
Story2	C30	Col 25x25	0	2,35	3,67	B.2.4-5d	10,16	B.2.4-7d	0,033	B.2.4-7h	0,031	0,095
Story2	C30	Col 25x25	122,5	0,251	0,39	B.2.4-5d	10,16	B.2.4-7d	0,033	B.2.4-7h	0,032	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story2	C30	Col 25x25	245	2,014	3,15	B.2.4-5d	10,16	B.2.4-7d	0,033	B.2.4-7h	0,032	0,095
Story2	C31	Col 25x25	0	2,84	4,44	B.2.4-5d	10,16	B.2.4-5d	0,027	B.2.4-5h	0,045	0,095
Story2	C31	Col 25x25	122,5	0,385	0,60	B.2.4-5h	10,16	B.2.4-5d	0,027	B.2.4-5h	0,045	
Story2	C31	Col 25x25	245	2,482	3,88	B.2.4-5d	10,16	B.2.4-5d	0,027	B.2.4-5h	0,045	0,095
Story2	C35	Col 25x25	0	1,919	3,00	B.2.4-5h	10,16	B.2.4-5d	0,082	B.2.4-5h	0,04	0,095
Story2	C35	Col 25x25	122,5	0,405	0,63	B.2.4-5h	10,16	B.2.4-5d	0,082	B.2.4-5h	0,04	
Story2	C35	Col 25x25	245	1,615	2,52	B.2.4-5d	10,16	B.2.4-5d	0,082	B.2.4-5h	0,04	0,095
Story2	C36	Col 25x25	0	2,882	4,50	B.2.4-5d	10,16	B.2.4-7d	0,032	B.2.4-5h	0,046	0,095
Story2	C36	Col 25x25	122,5	0,362	0,57	B.2.4-5h	10,16	B.2.4-7d	0,033	B.2.4-5h	0,046	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story2	C36	Col 25x25	245	2,536	3,96	B.2.4-5d	10,16	B.2.4-7d	0,033	B.2.4-5h	0,046	0,095
Story2	C37	Col 25x25	0	2,097	3,28	B.2.4-5d	10,16	B.2.4-5d	0,085	B.2.4-5h	0,059	0,095
Story2	C37	Col 25x25	122,5	0,177	0,28	B.2.4-5h	10,16	B.2.4-5d	0,085	B.2.4-5h	0,059	
Story2	C37	Col 25x25	245	1,922	3,00	B.2.4-5d	10,16	B.2.4-5d	0,085	B.2.4-5h	0,059	0,095
Story2	C39	Col 25x25	0	1,827	2,85	B.2.4-5d	10,16	B.2.4-5d	0,078	B.2.4-5h	0,036	0,095
Story2	C39	Col 25x25	122,5	0,389	0,61	B.2.4-7h	10,16	B.2.4-5d	0,078	B.2.4-5h	0,036	
Story2	C39	Col 25x25	245	1,514	2,37	B.2.4-5d	10,16	B.2.4-5d	0,078	B.2.4-5h	0,036	0,095
Story2	C40	Col 25x25	0	3,17	4,95	B.2.4-5d	10,16	B.2.4-5d	0,039	B.2.4-5h	0,048	0,095
Story2	C40	Col 25x25	122,5	0,365	0,57	B.2.4-5h	10,16	B.2.4-5d	0,04	B.2.4-5h	0,048	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story2	C40	Col 25x25	245	2,751	4,30	B.2.4-5d	10,16	B.2.4-5d	0,04	B.2.4-5h	0,048	0,095
Story2	C41	Col 25x25	0	2,246	3,51	B.2.4-5d	10,16	B.2.4-5d	0,089	B.2.4-5h	0,06	0,095
Story2	C41	Col 25x25	122,5	0,171	0,27	B.2.4-5h	10,16	B.2.4-5d	0,089	B.2.4-5h	0,06	
Story2	C41	Col 25x25	245	2,033	3,18	B.2.4-5d	10,16	B.2.4-5d	0,089	B.2.4-5h	0,06	0,095
Story2	C42	Col 25x25	0	2,617	4,09	B.2.4-5d	10,16	B.2.4-7d	0,028	B.2.4-5h	0,028	0,095
Story2	C42	Col 25x25	122,5	0,326	0,51	B.2.4-5d	10,16	B.2.4-7d	0,028	B.2.4-5h	0,029	
Story2	C42	Col 25x25	245	2,143	3,35	B.2.4-5d	10,16	B.2.4-7d	0,028	B.2.4-5h	0,029	0,095
Story2	C43	Col 25x25	0	2,724	4,26	B.2.4-5d	10,16	B.2.4-7d	0,031	B.2.4-5h	0,035	0,095
Story2	C43	Col 25x25	122,5	0,315	0,49	B.2.4-5d	10,16	B.2.4-7d	0,031	B.2.4-5h	0,036	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story2	C43	Col 25x25	245	2,352	3,68	B.2.4-5d	10,16	B.2.4-7d	0,031	B.2.4-5h	0,036	0,095
Story2	C44	Col 25x25	0	2,511	3,92	B.2.4-5d	10,16	B.2.4-7d	0,081	B.2.4-7d	0,063	0,095
Story2	C44	Col 25x25	122,5	0,257	0,40	B.2.4-5d	10,16	B.2.4-7d	0,081	B.2.4-7d	0,063	
Story2	C44	Col 25x25	245	2,161	3,38	B.2.4-5d	10,16	B.2.4-7d	0,081	B.2.4-7d	0,063	0,095
Story2	C46	Col 25x25	0	1,719	2,69	B.2.4-5d	10,16	B.2.4-5d	0,055	B.2.4-5h	0,063	0,095
Story2	C46	Col 25x25	122,5	0,247	0,39	B.2.4-7d	10,16	B.2.4-5d	0,055	B.2.4-5h	0,063	
Story2	C46	Col 25x25	245	1,603	2,50	B.2.4-5d	10,16	B.2.4-5d	0,055	B.2.4-5h	0,063	0,095
Story2	C47	Col 25x25	0	1,968	3,08	B.2.4-5d	10,16	B.2.4-5d	0,052	B.2.4-5h	0,083	0,095
Story2	C47	Col 25x25	122,5	0,188	0,29	B.2.4-5d	10,16	B.2.4-5d	0,052	B.2.4-5h	0,083	
Story2	C47	Col 25x25	245	1,807	2,82	B.2.4-5d	10,16	B.2.4-5d	0,052	B.2.4-5h	0,083	0,095

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story2	C48	Col 25x25	0	2,334	3,65	B.2.4-5d	10,16	B.2.4-5d	0,066	B.2.4-7h	0,085	0,095
Story2	C48	Col 25x25	122,5	0,256	0,40	B.2.4-5d	10,16	B.2.4-5d	0,066	B.2.4-7h	0,085	
Story2	C48	Col 25x25	245	1,862	2,91	B.2.4-7d	10,16	B.2.4-5d	0,066	B.2.4-7h	0,085	0,095
Story2	C49	Col 25x25	0	2,507	3,92	B.2.4-5d	10,16	B.2.4-5d	0,069	B.2.4-5h	0,089	0,095
Story2	C49	Col 25x25	122,5	0,285	0,45	B.2.4-5d	10,16	B.2.4-5d	0,069	B.2.4-5h	0,089	
Story2	C49	Col 25x25	245	2,017	3,15	B.2.4-5d	10,16	B.2.4-5d	0,069	B.2.4-5h	0,089	0,095
Story2	C50	Col 25x25	0	2,017	3,15	B.2.4-5d	10,16	B.2.4-5d	0,048	B.2.4-5h	0,088	0,095
Story2	C50	Col 25x25	122,5	0,259	0,40	B.2.4-5h	10,16	B.2.4-5d	0,048	B.2.4-5h	0,088	
Story2	C50	Col 25x25	245	1,913	2,99	B.2.4-5d	10,16	B.2.4-5d	0,048	B.2.4-5h	0,088	0,095
Story2	C51	Col 25x25	0	1,507	2,35	B.2.4-5d	10,16	B.2.4-5d	0,05	B.2.4-5h	0,06	0,095

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story2	C51	Col 25x25	122,5	0,155	0,24	B.2.4-5d	10,16	B.2.4-5d	0,05	B.2.4-5h	0,06	
Story2	C51	Col 25x25	245	1,557	2,43	B.2.4-5d	10,16	B.2.4-5d	0,05	B.2.4-5h	0,06	0,095
Story2	C54	Col 25x25	0	3,095	4,84	B.2.4-5d	10,16	B.2.4-5d	0,029	B.2.4-5h	0,047	0,095
Story2	C54	Col 25x25	122,5	0,4	0,63	B.2.4-5h	10,16	B.2.4-5d	0,029	B.2.4-5h	0,047	
Story2	C54	Col 25x25	245	2,703	4,22	B.2.4-5d	10,16	B.2.4-5d	0,029	B.2.4-5h	0,048	0,095
Story1	C1	Col 25x25	0	3,275	5,12	B.2.4-5h	10,16	B.2.4-5d	0,076	B.2.4-5h	0,1	0,095
Story1	C1	Col 25x25	122,5	1,079	1,69	B.2.4-7h	10,16	B.2.4-5d	0,076	B.2.4-5h	0,1	
Story1	C1	Col 25x25	245	1,651	2,58	B.2.4-5d	10,16	B.2.4-5d	0,076	B.2.4-5h	0,1	0,095
Story1	C2	Col 25x25	0	3,465	5,41	B.2.4-5h	10,16	B.2.4-5d	0,086	B.2.4-5h	0,106	0,095
Story1	C2	Col 25x25	122,5	1,124	1,76	B.2.4-7h	10,16	B.2.4-5d	0,086	B.2.4-5h	0,106	
Story1	C2	Col 25x25	245	1,817	2,84	B.2.4-5d	10,16	B.2.4-5d	0,086	B.2.4-5h	0,106	0,095
Story1	C3	Col 25x25	0	4,905	7,66	B.2.4-5h	10,16	B.2.4-7d	0,024	B.2.4-7h	0,088	0,095

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story1	C3	Col 25x25	122,5	1,271	1,99	B.2.4-5h	10,16	B.2.4-7d	0,024	B.2.4-7h	0,089	
Story1	C3	Col 25x25	245	3,358	5,25	B.2.4-5h	10,16	B.2.4-7d	0,024	B.2.4-7h	0,089	0,095
Story1	C4	Col 25x25	0	5,047	7,89	B.2.4-5h	10,16	B.2.4-7d	0,024	B.2.4-7h	0,081	0,095
Story1	C4	Col 25x25	122,5	1,352	2,11	B.2.4-5h	10,16	B.2.4-7d	0,025	B.2.4-7h	0,081	
Story1	C4	Col 25x25	245	3,246	5,07	B.2.4-5h	10,16	B.2.4-7d	0,025	B.2.4-7h	0,081	0,095
Story1	C5	Col 25x25	0	3,811	5,95	B.2.4-5h	10,16	B.2.4-5d	0,082	B.2.4-5h	0,113	0,095
Story1	C5	Col 25x25	122,5	1,075	1,68	B.2.4-5h	10,16	B.2.4-5d	0,082	B.2.4-5h	0,113	
Story1	C5	Col 25x25	245	1,949	3,05	B.2.4-5h	10,16	B.2.4-5d	0,082	B.2.4-5h	0,113	0,095
Story1	C6	Col 25x25	0	3,146	4,92	B.2.4-5h	10,16	B.2.4-5d	0,083	B.2.4-5h	0,096	0,095
Story1	C6	Col 25x25	122,5	0,877	1,37	B.2.4-7h	10,16	B.2.4-5d	0,083	B.2.4-5h	0,096	
Story1	C6	Col 25x25	245	1,638	2,56	B.2.4-5d	10,16	B.2.4-5d	0,083	B.2.4-5h	0,096	0,095
Story1	C7	Col 25x25	0	4,064	6,35	B.2.4-5h	10,16	B.2.4-7d	0,038	B.2.4-7h	0,069	0,095
Story1	C7	Col 25x25	122,5	1,027	1,60	B.2.4-5h	10,16	B.2.4-7d	0,038	B.2.4-7h	0,069	
Story1	C7	Col 25x25	245	2,631	4,11	B.2.4-5h	10,16	B.2.4-7d	0,038	B.2.4-7h	0,069	0,095
Story1	C8	Col 25x25	0	4,374	6,83	B.2.4-5h	10,16	B.2.4-7d	0,048	B.2.4-7h	0,062	0,095

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story1	C8	Col 25x25	122,5	1,097	1,71	B.2.4-5h	10,16	B.2.4-7d	0,048	B.2.4-7h	0,063	
Story1	C8	Col 25x25	245	2,729	4,26	B.2.4-5h	10,16	B.2.4-7d	0,048	B.2.4-7h	0,063	0,095
Story1	C9	Col 25x25	0	3,573	5,58	B.2.4-5h	10,16	B.2.4-5d	0,095	B.2.4-5h	0,099	0,095
Story1	C9	Col 25x25	122,5	0,969	1,51	B.2.4-5h	10,16	B.2.4-5d	0,095	B.2.4-5h	0,099	
Story1	C9	Col 25x25	245	1,869	2,92	B.2.4-5h	10,16	B.2.4-5d	0,095	B.2.4-5h	0,099	0,095
Story1	C10	Col 25x25	0	3,011	4,70	B.2.4-5h	10,16	B.2.4-5d	0,086	B.2.4-5h	0,09	0,095
Story1	C10	Col 25x25	122,5	0,892	1,39	B.2.4-7h	10,16	B.2.4-5d	0,086	B.2.4-5h	0,09	
Story1	C10	Col 25x25	245	1,625	2,54	B.2.4-5d	10,16	B.2.4-5d	0,086	B.2.4-5h	0,09	0,095
Story1	C11	Col 25x25	0	3,803	5,94	B.2.4-5h	10,16	B.2.4-7d	0,039	B.2.4-7h	0,063	0,095
Story1	C11	Col 25x25	122,5	0,92	1,44	B.2.4-5h	10,16	B.2.4-7d	0,039	B.2.4-7h	0,063	
Story1	C11	Col 25x25	245	2,478	3,87	B.2.4-5h	10,16	B.2.4-7d	0,039	B.2.4-7h	0,063	0,095
Story1	C12	Col 25x25	0	3,487	5,45	B.2.4-5d	10,16	B.2.4-7d	0,1	B.2.4-7d	0,056	0,095
Story1	C12	Col 25x25	122,5	1,015	1,59	B.2.4-5h	10,16	B.2.4-7d	0,1	B.2.4-7h	0,089	
Story1	C12	Col 25x25	245	2,174	3,40	B.2.4-5d	10,16	B.2.4-7d	0,1	B.2.4-7h	0,089	0,095
Story1	C13	Col 25x25	0	2,771	4,33	B.2.4-5h	10,16	B.2.4-5d	0,079	B.2.4-5h	0,083	0,095

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story1	C13	Col 25x25	122,5	0,743	1,16	B.2.4-5h	10,16	B.2.4-5d	0,079	B.2.4-5h	0,083	
Story1	C13	Col 25x25	245	1,429	2,23	B.2.4-5h	10,16	B.2.4-5d	0,079	B.2.4-5h	0,083	0,095
Story1	C14	Col 25x25	0	3,714	5,80	B.2.4-5h	10,16	B.2.4-7d	0,026	B.2.4-7h	0,05	0,095
Story1	C14	Col 25x25	122,5	0,968	1,51	B.2.4-5h	10,16	B.2.4-7d	0,026	B.2.4-7h	0,05	
Story1	C14	Col 25x25	245	2,412	3,77	B.2.4-5h	10,16	B.2.4-7d	0,026	B.2.4-7h	0,05	0,095
Story1	C15	Col 25x25	0	3,994	6,24	B.2.4-5h	10,16	B.2.4-7d	0,035	B.2.4-7h	0,046	0,095
Story1	C15	Col 25x25	122,5	1,004	1,57	B.2.4-5h	10,16	B.2.4-7d	0,035	B.2.4-7h	0,046	
Story1	C15	Col 25x25	245	2,519	3,94	B.2.4-5h	10,16	B.2.4-7d	0,035	B.2.4-7h	0,046	0,095
Story1	C16	Col 25x25	0	3,177	4,96	B.2.4-5h	10,16	B.2.4-5d	0,094	B.2.4-5h	0,084	0,095
Story1	C16	Col 25x25	122,5	0,865	1,35	B.2.4-5h	10,16	B.2.4-5d	0,094	B.2.4-5h	0,084	
Story1	C16	Col 25x25	245	1,656	2,59	B.2.4-5h	10,16	B.2.4-5d	0,094	B.2.4-5h	0,084	0,095
Story1	C17	Col 25x25	0	2,587	4,04	B.2.4-5h	10,16	B.2.4-5d	0,079	B.2.4-5h	0,076	0,095
Story1	C17	Col 25x25	122,5	0,689	1,08	B.2.4-5h	10,16	B.2.4-5d	0,079	B.2.4-5h	0,076	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story1	C17	Col 25x25	245	1,362	2,13	B.2.4-5d	10,16	B.2.4-5d	0,079	B.2.4-5h	0,076	0,095
Story1	C18	Col 25x25	0	3,494	5,46	B.2.4-5h	10,16	B.2.4-7d	0,026	B.2.4-7h	0,041	0,095
Story1	C18	Col 25x25	122,5	0,922	1,44	B.2.4-5h	10,16	B.2.4-7d	0,026	B.2.4-7h	0,041	
Story1	C18	Col 25x25	245	2,281	3,56	B.2.4-5h	10,16	B.2.4-7d	0,026	B.2.4-7h	0,041	0,095
Story1	C19	Col 25x25	0	3,741	5,85	B.2.4-5h	10,16	B.2.4-7d	0,036	B.2.4-7h	0,04	0,095
Story1	C19	Col 25x25	122,5	0,923	1,44	B.2.4-5h	10,16	B.2.4-7d	0,037	B.2.4-7h	0,04	
Story1	C19	Col 25x25	245	2,401	3,75	B.2.4-5h	10,16	B.2.4-7d	0,037	B.2.4-7h	0,04	0,095
Story1	C20	Col 25x25	0	3,033	4,74	B.2.4-5d	10,16	B.2.4-5d	0,1	B.2.4-5h	0,076	0,095
Story1	C20	Col 25x25	122,5	0,771	1,20	B.2.4-5h	10,16	B.2.4-5d	0,1	B.2.4-5h	0,076	
Story1	C20	Col 25x25	245	1,639	2,56	B.2.4-5d	10,16	B.2.4-5d	0,1	B.2.4-5h	0,076	0,095
Story1	C21	Col 25x25	0	2,882	4,50	B.2.4-5h	10,16	B.2.4-5d	0,074	B.2.4-5h	0,086	0,095
Story1	C21	Col 25x25	122,5	0,697	1,09	B.2.4-5h	10,16	B.2.4-5d	0,074	B.2.4-5h	0,086	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story1	C21	Col 25x25	245	1,658	2,59	B.2.4-5h	10,16	B.2.4-5d	0,074	B.2.4-5h	0,086	0,095
Story1	C22	Col 25x25	0	2,659	4,15	B.2.4-5h	10,16	B.2.4-5d	0,067	B.2.4-5h	0,078	0,095
Story1	C22	Col 25x25	122,5	0,681	1,06	B.2.4-5h	10,16	B.2.4-5d	0,067	B.2.4-5h	0,078	
Story1	C22	Col 25x25	245	1,382	2,16	B.2.4-5h	10,16	B.2.4-5d	0,067	B.2.4-5h	0,078	0,095
Story1	C23	Col 25x25	0	2,602	4,07	B.2.4-5h	10,16	B.2.4-5d	0,068	B.2.4-5h	0,082	0,095
Story1	C23	Col 25x25	122,5	0,645	1,01	B.2.4-5d	10,16	B.2.4-5d	0,068	B.2.4-5h	0,082	
Story1	C23	Col 25x25	245	1,431	2,24	B.2.4-5h	10,16	B.2.4-5d	0,068	B.2.4-5h	0,082	0,095
Story1	C24	Col 25x25	0	2,647	4,14	B.2.4-5h	10,16	B.2.4-7d	0,081	B.2.4-7d	0,061	0,095
Story1	C24	Col 25x25	122,5	0,562	0,88	B.2.4-5d	10,16	B.2.4-7d	0,081	B.2.4-7h	0,084	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story1	C24	Col 25x25	245	1,557	2,43	B.2.4-5h	10,16	B.2.4-7d	0,081	B.2.4-7h	0,084	0,095
Story1	C25	Col 25x25	0	3,303	5,16	B.2.4-5d	10,16	B.2.4-7d	0,032	B.2.4-7h	0,034	0,095
Story1	C25	Col 25x25	122,5	0,843	1,32	B.2.4-5h	10,16	B.2.4-7d	0,032	B.2.4-7h	0,034	
Story1	C25	Col 25x25	245	2,16	3,38	B.2.4-5d	10,16	B.2.4-7d	0,032	B.2.4-7h	0,034	0,095
Story1	C26	Col 25x25	0	3,619	5,65	B.2.4-5d	10,16	B.2.4-7d	0,036	B.2.4-7h	0,034	0,095
Story1	C26	Col 25x25	122,5	0,896	1,40	B.2.4-5h	10,16	B.2.4-7d	0,036	B.2.4-7h	0,034	
Story1	C26	Col 25x25	245	2,299	3,59	B.2.4-5h	10,16	B.2.4-7d	0,036	B.2.4-7h	0,034	0,095
Story1	C27	Col 25x25	0	3,013	4,71	B.2.4-5d	10,16	B.2.4-5d	0,098	B.2.4-5h	0,071	0,095
Story1	C27	Col 25x25	122,5	0,748	1,17	B.2.4-5h	10,16	B.2.4-5d	0,098	B.2.4-5h	0,071	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story1	C27	Col 25x25	245	1,598	2,50	B.2.4-5d	10,16	B.2.4-5d	0,098	B.2.4-5h	0,071	0,095
Story1	C28	Col 25x25	0	3,283	5,13	B.2.4-5h	10,16	B.2.4-7d	0,033	B.2.4-7h	0,026	0,095
Story1	C28	Col 25x25	122,5	0,767	1,20	B.2.4-5h	10,16	B.2.4-7d	0,033	B.2.4-7h	0,026	
Story1	C28	Col 25x25	245	2,197	3,43	B.2.4-5h	10,16	B.2.4-7d	0,033	B.2.4-7h	0,026	0,095
Story1	C29	Col 25x25	0	3,275	5,12	B.2.4-5d	10,16	B.2.4-7d	0,033	B.2.4-7h	0,029	0,095
Story1	C29	Col 25x25	122,5	0,764	1,19	B.2.4-5h	10,16	B.2.4-7d	0,033	B.2.4-7h	0,029	
Story1	C29	Col 25x25	245	2,132	3,33	B.2.4-5d	10,16	B.2.4-7d	0,033	B.2.4-7h	0,029	0,095
Story1	C30	Col 25x25	0	2,975	4,65	B.2.4-5d	10,16	B.2.4-7d	0,035	B.2.4-7h	0,03	0,095
Story1	C30	Col 25x25	122,5	0,622	0,97	B.2.4-5d	10,16	B.2.4-7d	0,035	B.2.4-7h	0,03	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story1	C30	Col 25x25	245	1,87	2,92	B.2.4-5d	10,16	B.2.4-7d	0,035	B.2.4-7h	0,03	0,095
Story1	C31	Col 25x25	0	3,593	5,61	B.2.4-5d	10,16	B.2.4-7d	0,03	B.2.4-7h	0,028	0,095
Story1	C31	Col 25x25	122,5	0,939	1,47	B.2.4-5h	10,16	B.2.4-7d	0,03	B.2.4-7h	0,028	
Story1	C31	Col 25x25	245	2,374	3,71	B.2.4-5d	10,16	B.2.4-7d	0,03	B.2.4-7h	0,028	0,095
Story1	C34	Col 25x25	0	3,034	4,74	B.2.4-5h	10,16	B.2.4-5d	0,098	B.2.4-5h	0,083	0,095
Story1	C34	Col 25x25	122,5	0,554	0,87	B.2.4-7h	10,16	B.2.4-5d	0,098	B.2.4-5h	0,083	
Story1	C34	Col 25x25	245	2	3,13	B.2.4-5h	10,16	B.2.4-5d	0,098	B.2.4-5h	0,083	0,095
Story1	C35	Col 25x25	0	2,825	4,41	B.2.4-5h	10,16	B.2.4-7d	0,078	B.2.4-5h	0,082	0,095
Story1	C35	Col 25x25	122,5	0,575	0,90	B.2.4-5h	10,16	B.2.4-7d	0,078	B.2.4-5h	0,082	
Story1	C35	Col 25x25	245	1,706	2,67	B.2.4-5h	10,16	B.2.4-7d	0,078	B.2.4-5h	0,082	0,095

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story1	C36	Col 25x25	0	3,71	5,80	B.2.4-5d	10,16	B.2.4-7d	0,04	B.2.4-7h	0,03	0,095
Story1	C36	Col 25x25	122,5	0,93	1,45	B.2.4-5d	10,16	B.2.4-7d	0,04	B.2.4-7h	0,03	
Story1	C36	Col 25x25	245	2,45	3,83	B.2.4-5d	10,16	B.2.4-7d	0,04	B.2.4-7h	0,03	0,095
Story1	C37	Col 25x25	0	3,106	4,85	B.2.4-5d	10,16	B.2.4-5d	0,101	B.2.4-5h	0,067	0,095
Story1	C37	Col 25x25	122,5	0,737	1,15	B.2.4-5d	10,16	B.2.4-5d	0,101	B.2.4-5h	0,067	
Story1	C37	Col 25x25	245	1,672	2,61	B.2.4-5d	10,16	B.2.4-5d	0,101	B.2.4-5h	0,067	0,095
Story1	C38	Col 25x25	0	2,99	4,67	B.2.4-5h	10,16	B.2.4-5d	0,096	B.2.4-5h	0,083	0,095
Story1	C38	Col 25x25	122,5	0,555	0,87	B.2.4-5h	10,16	B.2.4-5d	0,096	B.2.4-5h	0,083	
Story1	C38	Col 25x25	245	1,98	3,09	B.2.4-5d	10,16	B.2.4-5d	0,096	B.2.4-5h	0,083	0,095
Story1	C39	Col 25x25	0	2,646	4,13	B.2.4-5h	10,16	B.2.4-5d	0,074	B.2.4-5h	0,077	0,095
Story1	C39	Col 25x25	122,5	0,617	0,96	B.2.4-5d	10,16	B.2.4-5d	0,074	B.2.4-5h	0,077	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story1	C39	Col 25x25	245	1,468	2,29	B.2.4-5h	10,16	B.2.4-5d	0,074	B.2.4-5h	0,077	0,095
Story1	C40	Col 25x25	0	3,978	6,22	B.2.4-5d	10,16	B.2.4-7d	0,045	B.2.4-7h	0,03	0,095
Story1	C40	Col 25x25	122,5	0,922	1,44	B.2.4-5d	10,16	B.2.4-7d	0,046	B.2.4-7h	0,03	
Story1	C40	Col 25x25	245	2,671	4,17	B.2.4-5d	10,16	B.2.4-7d	0,046	B.2.4-7h	0,03	0,095
Story1	C41	Col 25x25	0	3,209	5,01	B.2.4-5d	10,16	B.2.4-5d	0,104	B.2.4-5h	0,066	0,095
Story1	C41	Col 25x25	122,5	0,735	1,15	B.2.4-5d	10,16	B.2.4-5d	0,104	B.2.4-5h	0,066	
Story1	C41	Col 25x25	245	1,76	2,75	B.2.4-5d	10,16	B.2.4-5d	0,104	B.2.4-5h	0,066	0,095
Story1	C42	Col 25x25	0	3,175	4,96	B.2.4-5d	10,16	B.2.4-7d	0,03	B.2.4-7h	0,021	0,095
Story1	C42	Col 25x25	122,5	0,801	1,25	B.2.4-5d	10,16	B.2.4-7d	0,03	B.2.4-7h	0,021	
Story1	C42	Col 25x25	245	2,008	3,14	B.2.4-5d	10,16	B.2.4-7d	0,03	B.2.4-7h	0,021	0,095

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story1	C43	Col 25x25	0	3,445	5,38	B.2.4-5d	10,16	B.2.4-7d	0,031	B.2.4-7h	0,026	0,095
Story1	C43	Col 25x25	122,5	0,782	1,22	B.2.4-5d	10,16	B.2.4-7d	0,031	B.2.4-7h	0,026	
Story1	C43	Col 25x25	245	2,233	3,49	B.2.4-5d	10,16	B.2.4-7d	0,031	B.2.4-7h	0,026	0,095
Story1	C44	Col 25x25	0	3,162	4,94	B.2.4-5d	10,16	B.2.4-7d	0,035	B.2.4-7h	0,028	0,095
Story1	C44	Col 25x25	122,5	0,68	1,06	B.2.4-5d	10,16	B.2.4-7d	0,035	B.2.4-7h	0,028	
Story1	C44	Col 25x25	245	1,991	3,11	B.2.4-5d	10,16	B.2.4-7d	0,035	B.2.4-7h	0,028	0,095
Story1	C45	Col 25x25	0	2,822	4,41	B.2.4-5d	10,16	B.2.4-7d	0,073	B.2.4-5h	0,083	0,095
Story1	C45	Col 25x25	122,5	0,697	1,09	B.2.4-5d	10,16	B.2.4-7d	0,073	B.2.4-5h	0,083	
Story1	C45	Col 25x25	245	1,618	2,53	B.2.4-5h	10,16	B.2.4-7d	0,073	B.2.4-5h	0,083	0,095
Story1	C46	Col 25x25	0	2,769	4,33	B.2.4-5d	10,16	B.2.4-5d	0,067	B.2.4-5h	0,074	0,095

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story1	C46	Col 25x25	122,5	0,74	1,16	B.2.4-5d	10,16	B.2.4-5d	0,067	B.2.4-5h	0,074	
Story1	C46	Col 25x25	245	1,42	2,22	B.2.4-5d	10,16	B.2.4-5d	0,067	B.2.4-5h	0,074	0,095
Story1	C47	Col 25x25	0	2,837	4,43	B.2.4-5d	10,16	B.2.4-5d	0,068	B.2.4-5h	0,078	0,095
Story1	C47	Col 25x25	122,5	0,727	1,14	B.2.4-5d	10,16	B.2.4-5d	0,068	B.2.4-5h	0,078	
Story1	C47	Col 25x25	245	1,508	2,36	B.2.4-5d	10,16	B.2.4-5d	0,068	B.2.4-5h	0,078	0,095
Story1	C48	Col 25x25	0	3,063	4,79	B.2.4-5d	10,16	B.2.4-5d	0,086	B.2.4-5h	0,081	0,095
Story1	C48	Col 25x25	122,5	0,645	1,01	B.2.4-5d	10,16	B.2.4-5d	0,086	B.2.4-5h	0,081	
Story1	C48	Col 25x25	245	1,861	2,91	B.2.4-5d	10,16	B.2.4-5d	0,086	B.2.4-5h	0,081	0,095
Story1	C49	Col 25x25	0	3,272	5,11	B.2.4-5d	10,16	B.2.4-7d	0,089	B.2.4-7h	0,077	0,095
Story1	C49	Col 25x25	122,5	0,77	1,20	B.2.4-5d	10,16	B.2.4-7d	0,089	B.2.4-7h	0,077	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story1	C49	Col 25x25	245	2,048	3,20	B.2.4-5d	10,16	B.2.4-7d	0,089	B.2.4-7h	0,077	0,095
Story1	C50	Col 25x25	0	3,267	5,10	B.2.4-5d	10,16	B.2.4-7d	0,073	B.2.4-7h	0,079	0,095
Story1	C50	Col 25x25	122,5	0,937	1,46	B.2.4-5d	10,16	B.2.4-7d	0,073	B.2.4-7h	0,079	
Story1	C50	Col 25x25	245	1,697	2,65	B.2.4-5d	10,16	B.2.4-7d	0,073	B.2.4-7h	0,079	0,095
Story1	C51	Col 25x25	0	2,945	4,60	B.2.4-5d	10,16	B.2.4-5d	0,078	B.2.4-5h	0,066	0,095
Story1	C51	Col 25x25	122,5	0,861	1,35	B.2.4-5d	10,16	B.2.4-5d	0,078	B.2.4-5h	0,066	
Story1	C51	Col 25x25	245	1,246	1,95	B.2.4-5d	10,16	B.2.4-5d	0,078	B.2.4-5h	0,066	0,095
Story1	C52	Col 25x25	0	3,044	4,76	B.2.4-5d	10,16	B.2.4-5d	0,082	B.2.4-5h	0,083	0,095
Story1	C52	Col 25x25	122,5	0,728	1,14	B.2.4-5d	10,16	B.2.4-5d	0,082	B.2.4-5h	0,083	

TRABAJO PROFESIONAL INTEGRADO

Piso	Label	Design Section	Station cm	PMM Ratio	PMM Ratio efectivo	PMM Combo	As cm²	V Major Combo	At V Major cm²/cm	V Minor Combo	At V Minor cm²/cm	Av sum. cm²/cm
Story1	C52	Col 25x25	245	1,822	2,85	B.2.4-5d	10,16	B.2.4-5d	0,082	B.2.4-5h	0,083	0,095
Story1	C53	Col 25x25	0	3,09	4,83	B.2.4-5d	10,16	B.2.4-5d	0,084	B.2.4-5h	0,082	0,095
Story1	C53	Col 25x25	122,5	0,725	1,13	B.2.4-5d	10,16	B.2.4-5d	0,084	B.2.4-5h	0,082	
Story1	C53	Col 25x25	245	1,836	2,87	B.2.4-5d	10,16	B.2.4-5d	0,084	B.2.4-5h	0,082	0,095
Story1	C54	Col 25x25	0	3,862	6,03	B.2.4-5d	10,16	B.2.4-7d	0,033	B.2.4-7h	0,027	0,095
Story1	C54	Col 25x25	122,5	1	1,56	B.2.4-5d	10,16	B.2.4-7d	0,033	B.2.4-7h	0,027	
Story1	C54	Col 25x25	245	2,579	4,03	B.2.4-5d	10,16	B.2.4-7d	0,033	B.2.4-7h	0,027	0,095